

CHARLES TOWN UTL-GLEN HAVEN UTILITIES

WV3301909

Consumer Confidence Report – 2023

Covering Calendar Year – 2022

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affects drinking water quality or if you have any questions, comments or suggestions, please attend any regularly scheduled water board meeting held on the 2nd and 4th Wednesday of each month at 4:00 p.m. in the Charles Town Utility Board Office, at 661 South George Street, Charles Town, WV 25414 or call KRISTEN M. STOLIPHER at 304-725-2316.

Your water comes from:

Source Name	Source Water Type
WELL #1	Ground Water

Buyer Name	Seller Name
There are no additional purchases to display.	

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system has an estimated population of 195 and is required to test a minimum of 1 sample per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2022 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2022. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): lab analysis indicates that the contaminant is not present.

Parts per Million (ppm) or milligrams per liter (mg/l)

Parts per Billion (ppb) or micrograms per liter (µg/l)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: CHARLES TOWN UTL-GLEN HAVEN UTILITIES

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2022				

Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	6/10/2019	0.0578	0.0578	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CADMIUM	6/10/2019	0.7	0.7	ppb	5	5	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; Runoff from waste batteries and paints
FLUORIDE	6/10/2019	0.11	0.11	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	4/4/2022	0.27	0.27	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	12/16/2019	0.66	0.66	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRITE	12/16/2019	0.4	0.4	ppm	1	1	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Sample	Monitorin	Highest	Range (low/high)	Unit	MC	MCL	Typical Source
-------------------------	--------	-----------	---------	------------------	------	----	-----	----------------

	Point	g Period	LRAA			L	G	
TTHM	925 MASON DRIVE (GLEN HAVEN PUMP HOUSE)	2022	2	2 - 2	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 th Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2020 - 2022	0.164	0.0321 - 0.206	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2020 - 2022	4.6	0.83 - 5.3	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The Charles Town Utility Board (CTUB) is working is working towards identifying service line materials throughout the water distribution supply. The service line inventory is required to be submitted to the state by October 16, 2024. If you have any questions about our inventory, please contact KRISTEN M. STOLIPHER at (304) 725-2316.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
2022 - 2022	1.9000	MG/L	1.6	MG/L

Radiological Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2022							

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
SODIUM	6/10/2019	12.8	12.8	MG/L	1000
SULFATE	6/10/2019	50.6	50.6	MG/L	250

During the 2022 calendar year, we had the below noted violation(s) of drinking water regulations.

Analyte: Volatile Organic Compounds

Compliance Period: 1/1/2020 to 12/31/2022

Violation Comments: Violation is noted for missing required Volatile Organic Compounds (VOC's) sample analyses results between 1/1/2020 and 12/31/2022. CTUB immediately sampled for these analytes upon notification that they were missing. The results from sampling are well within the requirements specified by the Environmental Protection Agency and the West Virginia Bureau of Public Health.

Analyte: Inorganic Compounds

Compliance Period: 1/1/2020 to 12/31/2022

Violation Comments: Violation is noted for missing required Inorganic Compounds (IOC's) sample analyses results between 1/1/2020 and 12/31/2022. CTUB immediately sampled for these analytes upon notification that they were missing. The results from sampling are well within the requirements specified by the Environmental Protection Agency and the West Virginia Bureau of Public Health.

Analyte: Arsenic

Compliance Period: 1/1/2020 to 12/31/2022

Violation Comments: Violation is noted for missing required Arsenic (ARS's) sample analyses results between 1/1/2020 and 12/31/2022. CTUB immediately sampled for these analytes upon notification that they were missing. The results from sampling are well within the requirements specified by the Environmental Protection Agency and the West Virginia Bureau of Public Health.

CTUB will work to correct this sample submission error in the future and will continue to strive to provide excellent water quality to our customers and strive to meet or exceed the standards set by the EPA and State of West Virginia.

Should you have any questions regarding this report or your drinking water quality please do not hesitate to contact us at info@ctubwv.com or (304) 725-2316.

Your CCR is available at www.ctubwv.com.

This report is hand-delivered to the residents within the Glen Haven Subdivision. Should you require an additional paper copy in the mail, please contact us at (304) 725-2316.